Silent Gliss Fabrics & components GmbH
Rheinauenstraβe 8
79415 Bad Bellingen
Germany

Your message - reference	our reference	Gent
-	PW/2938	2022-09-16

Certification report 22/2938

1. Description of the flooring:

Product	Sunscreen made of a 65% PVC and 35% PES surface
Mass	325 g/m²
Thickness	0.45 mm

2. Test results:

Classification according to EN 13501-1:2018 based on:

EN ISO 11925-2 (exposure=30s)	EN 13823

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.
Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

C – s2, d0

Mechanical fixation on top of the sample and free hanging over a 13 mm thick plasterboard (700 kg/m^3 or more) and all substrates classified A1 and A2-s1,d0 which density is superior to 525 kg/m^3

Related commercial names to this product group	Aluscreen futura
The obtained classification is based on the next test reports	Crepim: DO-22-4160/A-R1 dated 01-09-2022
Validity of the certificate	31/08/2027

Petra Wittevrongel

Product Certifier