Silent Gliss Fabrics & Components GmbH
Rheinauenstraße 8
79415 Bad Bellingen
Germany

Your message - reference	our reference	Gent
-	JW/4150	2025-11-26

Certification report 25/4150

1. Description of the material:

Product	Sunscreen made of a 75% PVC and 25%PES surface
Mass	420 g/m²
OF	5%
Thickness	0.55 mm

2. Test results:

Classification according to EN 13501-1:2007+A1 (2009) based on:

EN ISO 11925-2 (exposure=30s)	EN 13823

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.
Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

C – s3, d0

Mechanical fixation on top of the sample and free hanging over a 13 mm thick plasterboard (700 kg/m³ or more) and all substrates classified A1 and A2-s1,d0 which density is superior to 525 kg/m³

The evaluation of this properties is based on evaluation scheme specified in EN 13501-1:2019: Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests.

Related commercial names to this product group	Versascreen 5%
The obtained classification is based on the next test reports	Crepim: DO-25-7775/A-R1 dated 12-11-2025
Validity of the certificate	2030-11-11

Jo Wynendaele, PhD

Consultant Floor and Wall Coverings